

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood composite material**

Kind of material (wood): oak parquet element with on-site sealing
Article description: Bona Craft Oil 2K
Dimensions: length, width and thickness variable,
test specimen: 1000 x 500 x 27 [mm]
(oak parquet elements 1000 x 232 x 14 [mm],
cover width 215 mm)

Colour: dark oak
Surface: even, fine-rough structured, factory-sealed
(consumption: ca. 20-30 m²/litre)

Remark: manufacturer's processing recommendation:
2 x Bona Craft Oil 2K

Producer/supplier: Bona AB
Murmansgatan 130
200 21 Malmö
SWEDEN

Client: Bona Vertriebsgesellschaft mbH Deutschland
Jahnstraße 12
65549 Limburg

Certificate No.: 92292002.001e

Test date: 23.11.2020

Sampling: Sent by the customer to the research institute


Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property - Workrooms
and fields of activities with slip danger - Walking method - Ramp test"
The test material was delivered in a ready-to-test surface condition.

Test result: Average total acceptance angle: **15,4°**

Assessment: **Classification group of anti-slip property: R10**

SÄUREFLIESNER-VEREINIGUNG E. V.
Institut für Wand- und Bodenbeläge
Managing Director


Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 14.12.2020
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAkKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00
aufgeführten Bereiche. Von DIBt nach LBO unter der Kenn. Nr. NDS 20 anerkannt und nach EU BauDVO zertifizierte Stelle Nr. 1212

